

CERTIFICATE OF COMPLIANCE

Certificate Number 20161102-EX6908
Report Reference EX6908-20041008
Issue Date 2016-NOVEMBER-02

Issued to: BORUSAN MANNESMANN BORU AS
Meclisi Mebusan Caddesi 103
34427 TURKEY

**This is to certify that
representative samples of** METALLIC SPRINKLER PIPE
See Addendum Page for Models

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 852, Metallic Sprinkler Pipe for Fire Protection Service
ULC/ORD C199S, Light Wall Steel Pipes for Sprinkler
Systems for Fire Protection Service

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20161102-EX6908
Report Reference EX6908-20041008
Issue Date 2016-NOVEMBER-02

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

USL, CNL Schedule 10 and Schedule 40 steel sprinkler pipe intended for use in wet, dry, preaction and deluge type sprinkler systems.


Schedule 10 pipe with unthreaded ends is intended to be joined by welding or Listed Rubber Gasketed Fittings installed in accordance with the fitting manufacturer's specifications.

Schedule 40 pipe with threaded ends conforming to ANSI B1.20.1 is intended to be joined by threaded fittings, welding or Listed Rubber Gasketed Fittings installed in accordance with the fitting manufacturer's specification.

Pipe Schedule	Pipe Size, in.
Schedule 10	3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6, 8, 10
Schedule 40	1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6, 8, 10

USL - EN 10255 Medium steel pipe, 1-1/4 through 6-1/2 OD in. size for wet, dry, preaction and deluge type sprinkler systems with unthreaded ends intended to be joined by welding or by Listed rubber gasketed fittings as indicated in the individual listings under the category for Fittings, Rubber gasketed (VIZM) when installed in accordance with the fitting manufacturer's installation instruction where rated pressures and corrosion resistance ratio (CRR) are as follows:

Pipe Size In.	Rated Pressure (psig)	CRR Unthreaded
1-1/4	175	10.99
1-1/2	175	8.76
2	175	10.11
3	175	5.80
3 OD	175	5.77
4	175	5.21
5-1/2 OD	175	4.76
6-1/2 OD	175	3.22



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

