



Certificate of Compliance

This certificate is issued for the following:

Steel Pipe for Automatic Fire Sprinkler Systems

Schedule 10
Sizes 1 Through 8 inch NPS

and

Schedule 30, 40, & 80
Sizes 1 Through 10 inch NPS

Prepared for:

Borusan Birleşik Boru Fabrikaları Sanayi ve Ticaret A.Ş.
Ata Mah. Sanayi Cad. No 54/68
16601 Gemlik - Bursa,
Turkiye

Approval Standard: FM 1630 (November 2013)

Approval Identification: 3025409
Revision Request: RR239755

Approval Granted: 19 February 2007
Date Authorized: 9 January 2024

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read "D. B. Fuller".

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
One Technology Way
Norwood, MA 02062



Member of the FM Global Group

