



Certificate of Compliance

This certificate is issued for the following:

Steel Pipe for Automatic Fire Sprinkler Systems

Pipe Specification

ASTM A795
ASTM A53
ASTM A53
EN 10255
EN 10255

Pipe Schedule

Schedule 10
Schedule 40
Schedule 80
Medium
Heavy

Pipe Size

10 and 12 inch NPS
1/2 and 3/4 inch NPS
1/2 and 3/4 inch NPS
33.7 through 165.1 mm NPS
21.3 through 165.1 mm NPS

Prepared for:

Borusan Birleşik Boru Fabrikaları Sanayi ve Ticaret A.Ş.
Ata Mah. Sanayi Cad. No 54/68
16601 Gemlik - Bursa,
Turkiye

Approval Standard: FM 1630 (November 2013)

Approval Identification: 3046815
Revision Request: RR239755

Approval Granted: 28 August 2014
Date Authorized: 9 January 2024

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read 'D.B. Fuller', is written over a horizontal line.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group

